





This is to certify that: Pelsan Aydinlatma Sanayi

ve Ticaret A.S

Cerkesli OSB Imes 5 Cad

No:12 Dilovasi

Izmit Turkey

Holds Certificate Number:

ENEC 614105

In respect of:

EN 60598-2-5 **Floodlights**

(hereinafter called the certificate holder), having been assessed against the requirements of the CENELEC Agreement on the use of a commonly agreed Mark of Conformity for products complying with European standards (in short the ENEC Agreement), the right and Licence to use the commonly agreed Mark of Conformity for products shown below in respect of the goods particularly described in the Appendix bearing the same number as the certificate.

Goods shall be produced by the certificate holder only at the address given above in accordance with the relevant European Standard as detailed above. The Certificate is granted subject to the Specific Rules for the ENEC Agreement and the BSI Administration scheme.

For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 2014-11-04

Latest Issue: 2017-09-19

Page: 1 of 4

EUROPEAN NORMS

...making excellence a habit."

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

ENEC Certificate

No. ENEC 614105

EN 60598-2-5:1998 used in conjunction with EN 60598-1:2008 + A11:2011.

Group 1 - LIYA series of LED floodlights

BSI Reference report No. TR/14/597 (8151696).

Class 1 product, Ta 25°C, IP66.

Code	Input rating	Power rating	Number of LEDs
5615 6721	230V 50Hz	86W	80
5615 6722	230V 50Hz	128W	80
5615 6723	230V 50Hz	171W	80
5615 6731	230V 50Hz	103W	96
5615 6732	230V 50Hz	154W	96
5615 6733	230V 50Hz	206W	96

First Issued: 2014-11-04 Latest Issue: 2017-09-19

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

ENEC Certificate

No. ENEC 614105

EN 60598-2-5:2015 used in conjunction with EN 60598-1:2014.

Group 2 - NAIRO series of LED floodlights

Reference report No. 1612182463

Class 1 product, Ta 25°C, IP66.

Code	Input rating	Power rating	Number of LEDs
5616 3661	230V 50Hz	50 W	48
5616 3671	230V 50Hz	75 W	48
5616 3681	230V 50Hz	100 W	48
5616 3691	230V 50Hz	125 W	64
5616 3781	230V 50Hz	150 W	64

First Issued: 2014-11-04 Latest Issue: 2017-09-19

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

ENEC Certificate

No. ENEC 614105

EN 60598-2-5:2015 used in conjunction with EN 60598-1:2014.

Group 3 - RIA series of LED floodlights

Reference report No. 1612182462

Class 1 product, Ta 25°C, IP66.

Туре	Code	Input rating	Power rating	Number of LEDs
Symmetric	5617 1752	230V 50Hz	100 W	48
Symmetric	5617 1762	230V 50Hz	125 W	48
Symmetric	5617 1772	230V 50Hz	150 W	48
Symmetric	5617 1881	230V 50Hz	180 W	240
Symmetric	5617 1891	230V 50Hz	200 W	240
Symmetric	5617 17331	230V 50Hz	240 W	240
Asymmetric	5617 1831	230V 50Hz	180 W	240
Asymmetric	5617 1841	230V 50Hz	200 W	240
Asymmetric	5617 1721	230V 50Hz	240 W	240

First Issued: 2014-11-04 Latest Issue: 2017-09-19

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.